

Government Of West Bengal Office Of The Divisional Fire Officer, Purulia West Bengal Fire & Emergency Services Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Memo no.: IND/WB/FES/20192020/55218

Date: 24-04-2023

From:

Divisional Fire Officer, Purulia
West Bengal Fire & Emergency Services

To: Nirmala Chitta Teachers Training Institute

Vill: Pabra (Paharigora), P.O: Tentulhity, P.S: Santaldih, Dist: Purulia, Pin:723155

Sub: Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+2 storied building under the group educational in favour of Nirmala Chitta Teachers Training Institute at the premises no: Nil, Vill: Pabra (Paharigora), Mouza: Pabra, Plot No: 1673, J.L. No:57, Kh. No:259,423, P.O: Tentulhity P.S: Santaldih, Dist: Purulia, Pin: - 723155.

This is in reference to your application no. 0125191231600021 dated 13-04-2023 regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+2 storied building under the group educational in favour of Nirmala Chitta Teachers Training Institute at the premises no: Nil, Vill: Pabra (Paharigora), Mouza: Pabra, Plot No: 1673, J.L. No:57, Kh. No:259,423, P.O: Tentulhity P.S: Santaldih, Dist: Purulia, Pin: - 723155.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1. Driveway must be free of any type of obstruction for easy movement of fire appliances.
- 2. No parking shall be allowed on the driveway.
- 3. Existing electrical wiring of the whole building shall be carefully checked in view of fire and life safety.
- 4. The teaching, nonteaching and security staff shall be knowledgeable about the installed firefighting equipment of the building and operate it in the event of fire and testing.
- 5. Mock fire practice and evacuation drills shall be performed periodically with the participation of all occupants of the buildings.
- 6. Switchgear room shall be protected with CO2 or DCP fire extinguishers which are conforming to I.S. specifications.

- 7. A crew of trained firefighting under the experienced officer shall be maintained around the clock for the safety of the building.
- 8. The arrangement shall be made for regular checking and testing for all the fire safety fixed installations and equipment in the buildings to keep perfectly good working conditions at all times.
- 9. The fire safety audit is to be conducted at regular intervals and to be recorded in the fire prevention maintenance on the register. .
- 10. Fire notice for firefighting and evacuation of the building shall be prepared and displayed in all vulnerable places of the building.
- 11. Any deviation and changes in the nature of the use of the building in respect of the submitted plan drawing without obtaining prior permission from the office, and the renewal of the fire safety certificate shall be treated as cancelled.
- 12. This renewal fire safety certificate is valid for 03(three) years and has to be renewed every three (03) years from the date of issue of this letter.
- 13. This certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding the performance of all the Fire Safety arrangements and installation of this building.

Digitally Signed.
Name: PLABAN AND DAY
Date: 28-Apr-2023 15-11-04
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Purulia West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191231600021.

Page: 2